

Memorandum

April 14, 2022

To: Commissioners of Poolesville

From: Wade Yost, Town Manager

RE: I & I Contract Addendum

I am requesting an additional \$137,318 be added to the current I & I rehabilitation contract.

During the video work on the lateral lines, we identified 11 laterals that were installed with a 90 degree tap and perpendicular to the main line, which is not in accordance with standard practices. In this configuration the line cannot be lined. Further, bricks and motor were used to support the connection, which is a major source of infiltration. It is also difficult to maintenance and issues have occurred in the past requiring emergency repairs.

Clark/Azar's recommendation is to excavate approximately 7' to 10' deep in the roadway over the main line, intercept the lateral at the 90-degree bend, and replace it with two 45-degree unit bends to resolve the alignment issue.

Based upon the submitted lump sum fee and the existing budget, the addendum for this additional work is \$137,318.00. The American Rescue Funds account will fund the expenditures.